## **Midwest Tank Company**

17368 197th Avenue Big Lake, MN 55309 US Tel: 763.263.0747

Fax: 763.263.0748

Email: info@midwesttankco.com

## Item # BBT-30 x 36, Boiler Blowdown Tanks


For boiler pressures up to 400 lbs. use 100 lb. ASME tanks.

These boiler blow-off tanks are built and labeled in accordance with the ASME Code and comply in all respects with the requirements set forth in the State of Minnesota Code for pressure vessels.

Minimum shell thickness is 3/8" and a wear plate of thickness equal to that of the shell is installed opposite the inlet opening.

Tanks are furnished with legs, manhole, openings for 1/2" pressure gage, 1/2" gage glass, 3/4" thermometer and other fittings. Tanks are painted one shop coat of prime paint unless specified otherwise.





Specifications	Tank	Size	Chart	Tank Size
Specifications	Ialin	SIZE	Ullait	Idlik Size

Specifications					
Min. Shell Thickness	3/8 in				
Tank Size Chart					
Tank Size	30 x 36 in				
Boiler Rating	26 to 50 hp				
Tank Size					
Dim. (A)	30 in				
Dim. (B)	36 in				
Dim. (C)	26 in				
Dim. (D)	11 in				
Dim. (E)	2 in				
Dim. (F)	5 in				
Dim. (G)	1 in				
Dim. (H)	14 in				
Dim. (J)	13 1/4 in				
Dim. (K)	11 in				