Midwest Tank Company

17368 197th Avenue Big Lake, MN 55309 US Tel: 763.263.0747

Tel: 763.263.0747 Fax: 763.263.0748

Email: info@midwesttankco.com

Item # BBT-30 x 48, Boiler Blowdown Tanks


For boiler pressures up to 400 lbs. use 100 lb. ASME tanks.

These boiler blow-off tanks are built and labeled in accordance with the ASME Code and comply in all respects with the requirements set forth in the State of Minnesota Code for pressure vessels.

Minimum shell thickness is 3/8" and a wear plate of thickness equal to that of the shell is installed opposite the inlet opening.

Tanks are furnished with legs, manhole, openings for 1/2" pressure gage, 1/2" gage glass, 3/4" thermometer and other fittings. Tanks are painted one shop coat of prime paint unless specified otherwise.





3	Speci	icat	ions	٠	Tank	: S	ize	Charl	٠	Tank	Size	

Specifications	
Min. Shell Thickness	3/8 in
Tank Size Chart	
Tank Size	30 x 48 in
Boiler Rating	51 to 75 hp
Tank Size	
Dim. (A)	30 in
Dim. (B)	48 in
Dim. (C)	32 in
Dim. (D)	11 in
Dim. (E)	2 in
Dim. (F)	5 in
Dim. (G)	1 in
Dim. (H)	14 in
Dim. (J)	13 1/4 in
Dim. (K)	11 in