

**Midwest Tank Company**  
 17368 197th Avenue  
 Big Lake, MN 55309 US  
 Tel: 763.263.0747  
 Fax: 763.263.0748  
 Email: [info@midwesttankco.com](mailto:info@midwesttankco.com)


## Item # BBT-42 x 66, Boiler Blowdown Tanks

For boiler pressures up to 400 lbs. use 100 lb. ASME tanks.

These boiler blow-off tanks are built and labeled in accordance with the ASME Code and comply in all respects with the requirements set forth in the State of Minnesota Code for pressure vessels.

Minimum shell thickness is 3/8" and a wear plate of thickness equal to that of the shell is installed opposite the inlet opening.

Tanks are furnished with legs, manhole, openings for 1/2" pressure gage, 1/2" gage glass, 3/4" thermometer and other fittings. Tanks are painted one shop coat of prime paint unless specified otherwise.



[Specifications](#) · [Tank Size Chart](#) · [Tank Size](#)

### Specifications

Min. Shell Thickness	3/8 in
----------------------	--------

### Tank Size Chart

Tank Size	42 x 66 in
Boiler Rating	251 to 600 hp

### Tank Size

Dim. (A)	42 in
Dim. (B)	66 in
Dim. (C)	42 in
Dim. (D)	15 1/2 in
Dim. (E)	2 1/2 in
Dim. (F)	6 in
Dim. (G)	1 1/2 in
Dim. (H)	15 1/4 in
Dim. (J)	19 in
Dim. (K)	15 in

