


Midwest Tank Company
 17368 197th Avenue
 Big Lake, MN 55309 US
 Tel: 763.263.0747
 Fax: 763.263.0748
 Email: info@midwesttankco.com

Item # CWBT-130, Chilled Water Buffer Tanks

1. Built in accordance with ASME section VIII, Div.1 2007, A08 stamped.
2. MAWP 125 PSI @ 300°F.
 MAEWP 0 PSI @ 300°F.
 MDMT -20°F @ 125 PSI
 Hydrotest @ 163 PSI
3. Corrosion allowance 0
4. Interior coating: None
5. Exterior coating: Shop Primer
6. Baffle material. 1/4" SA36
7. (2) 2" CPLG.'S added in shell for inspection.
8. 12" x 16" Manway required on 42" Dia. and, larger vessels.



Specifications

| | |
|----------------------------|------------------------------|
| Capacity | 130 gal |
| Diameter | 24 in |
| Height | 82 in |
| 150# Flange Options | 3 in 4 in 6 in 8 in |
| M.A.W.P. @ 300 °F | 125 psi |
| M.A.E.W.P. @ 300 °F | 0 psi |
| M.D.M.T. @ 125 psi | -20 °F |
| Exterior Coating | Shop Primer |
| Baffle Material | 1/4" SA36 |