Midwest Tank Company

17368 197th Avenue Big Lake, MN 55309 US Tel: 763.263.0747

Tel: 763.263.0747 Fax: 763.263.0748


Email: info@midwesttankco.com

Item # HHWST10, Horizontal Hot Water Storage Tanks

Manufactured in accordance with section VIII, ASME pressure vessel code. Fitting locations to be dimensioned from head and shell joint.

12 x 16 Manway Standards only on cement, phenolic lined, and all tanks 42" diameter and over. All others to have inspection openings as required by ASME code.





Specifications

| Coil Diameter | 10 |
|---------------|----------|
| Tank Diameter | 54-56 in |
| | |
| A | Cold In |
| Dim. (E) | 10 |
| Dim. (F) | 20 |
| G | Coil In |
| Н | Coil Out |