## **Midwest Tank Company**

17368 197th Avenue Big Lake, MN 55309 US Tel: 763.263.0747

Tel: 763.263.0747 Fax: 763.263.0748


Email: info@midwesttankco.com

## Item # HHWST6, Horizontal Hot Water Storage Tanks

Manufactured in accordance with section VIII, ASME pressure vessel code. Fitting locations to be dimensioned from head and shell joint.

12 x 16 Manway Standards only on cement, phenolic lined, and all tanks 42" diameter and over. All others to have inspection openings as required by ASME code.





## **Specifications**

Coil Diameter	6
Tank Diameter	36 in
A	Cold In
Dim. (E)	8
Dim. (E) Dim. (F)	16
G	Coil In
Н	Coil Out